



EDMUND G. BROWN JR.  
GOVERNOR



MATTHEW RODRIGUEZ  
SECRETARY FOR  
ENVIRONMENTAL PROTECTION

---

**State Water Resources Control Board**  
Division of Drinking Water

May 25, 2018

Marcum Illinois Elementary School  
2452 El Centro Blvd.  
East Nicolaus, CA 95659

Attention: Jimmie Eggers, Administrator

**SUBJECT: NOTICE OF VIOLATION NO 21-18N-007, PUBLIC WATER SYSTEM NO. 5100140 –  
FAILURE TO COLLECT A ROUTINE BACTERIOLOGICAL SAMPLE IN APRIL 2018.**

The California Code of Regulations (CCR), Title 22, Article 3, Section 64423, requires that each public water system collect routine bacteriological samples from the distribution system, based on the number of service connections or the population served.

Our records show that Marcum Illinois Elementary School (hereinafter, System) operates a nontransient - noncommunity water system, which is required to collect and report a minimum of one routine bacteriological water quality sample per month.

In reviewing our records, we note that **the System did not collect and/or report a routine bacteriological sample to the Division during the month of April 2018.**


Furthermore, the System violated permit condition no. 5 of Permit Amendment No. 01-02-93P51008A2 (issued June 6, 2017), in that **the System failed to collect a raw bacteriological sample at the well head at three-month intervals.** The last raw water sample received by the Division was collect in January of 2018.

These violations could require public notification within 30 days and a citation with possible fines.

**The System is required to note these failures in the 2018 Consumer Confidence Report.**

By sending this letter we are clearly informing the System about the routine sampling responsibilities under the CCR.

If you have any questions regarding this matter, please call Paul Rowe at (530) 224-4866 or me at (530) 224-4861.

  
Reese B. Crenshaw, P.E.  
Valley District Engineer  
DRINKING WATER FIELD  
OPERATIONS BRANCH

---

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

364 Knollcrest Drive, Suite 101, Redding, CA 96002 | [www.waterboards.ca.gov](http://www.waterboards.ca.gov)